

PRACTICAL INFO 1

When planning and realising a store for hazardous goods numerous individual aspects have to be brought into agreement with one another. This means that the types and amounts of the hazardous substances to be stored, local conditions and available space, legal regulations, official requirements and, last but not least, the available budget must all be taken into consideration. Our check list is intended to help you with this.

Please note that this list is intended to provide you with a guideline only. Each individual case must be considered separately. If you want to be completely sure, just give us a call. We will be pleased to advise you.

Check list for the storage of water-endangering and/or flammable liquids

Clear classification of the substances to be stored

Water-endangering liquids / flammable liquids (flammable substances)

- Collection volume
- Trough material resistance (e.g. for storage of aggressive media)
- Type of containers (small containers, 200 L drums, IBCs...)
- Number of containers
- Walk-in store or storage racks
- Existing or planned handling devices
- Water protection area
- Official requirements



Water-endangering liquids



Flammable liquids (flammable substances)

- Location
- F90 system, F90 wall or at least 10 m distance from other building
- Ventilation
- Electrical equipment in Ex-protected zone
- Official requirements and/or technical requirements of fire brigade
- Fire protection requirements (fire extinction system, fire alarm, fire-fighting water retention system...)



In addition to all this, further information about the container and/or pallet sizes to be used, max. shelf loading or compartment heights required would be helpful and enable us to draw up an offer for you.